ATTACHMENT D

Notice of Alleged Safety or Health Hazards Mon Apr 14, 2003 4:16pm

Establishment Name	Federal Correctional Institute	Complaint Number	200381895
Site Address	Rt. 59 and Big Shanty Rd., I		
	Site Phone (814) 362-8900	Site FAX	(814) 363-6811
Mailing Address	P.O. Box 5000, Bradford, PA 16701		
	Mail Phone (814) 632-8900	Mail FAX	(814) 363-6811
Management Official	Stephen Housler, Safety	Telephone	
Type of Business	Federal Corrections	Ownership	
Primary SIC	9223	Primary NAICS	922140

- 1. Ventilation is inadequate to control the hazards associated dusts generated during the production processes. These dusts include but are not limited to wood dust, particle board dust, and micore board dust.
- 2. Ventilation is inadequate to control the hazards associated with vapors that are produced by the glues utilized in the laminating processes.
- 3. Dust is accumulating on surfaces throughout the factory area. This dust includes but is not limited to wood dust, particle board dust, and micore board dust.
- 4. Personnel are smoking in close proximity to operations that produce wood dust and utilize flammable glues.
- Compressed air above 30 psi is being utilized for blow-downs and cleaning operations.
- . lexi-glass and plywood are being stored on top of electrical boxes. Electrical boxes are located in the back by the dock area.
- 7. Personnel are potentially exposed to a fire hazard from a heavy accumulation of scrap wood at the loading dock area.

LOCATION:

UNICOR Factory (Including but not Limited To):

- * Loading Dock Area
- * Saw Area
- * Laminating Area, Front Area by Office